

GENERAL NOTES

ELECTRICAL NOTES

1. ALL WIRING SHALL BE IN ACCORDANCE WITH THE NATIONAL ELECTRIC CODE (NFPA700, NEC-2005).
2. ALL ELECTRICAL MATERIALS SHALL BE U.L. LISTED AND CLASSIFIED AS SUITABLE FOR THE PURPOSE SPECIFIED.
3. ALL WIRING SHALL BE SURFACE MOUNTED IN A RACEWAY OR EMT CONDUIT USING APPROVED CONNECTORS, COUPLINGS, AND CLAMPS, ALL CONDUIT SHALL BE ANCHORED IN PLACE AT APPROXIMATELY EVERY 4 FT.
4. ALL WIRING SHALL BE A SOLID CONDUCTOR, THHN OR THWN COPPER, NO SMALLER THAN A #12.
5. ALL WIRE RUNS SHALL BE CONTINUOUS.
6. LOW VOLTAGE WIRE MAY BE STRANDED.
7. ALL WIRING SHALL BE TESTED AND INSPECTED PRIOR TO SHIPMENT.
8. GREEN GROUND CONDUCTORS SHALL BE RUN TO ALL OF THE BUILDINGS A/C POWERED DEVICES. CONDUIT SHALL NOT BE USED AS THE SOLE SOURCE OF GROUND.
9. ALL ALARM DEVICES WIRING SHALL BE RUN IN ITS OWN CONDUIT TO THE ALARM CABINET.

24 OF 33

A-139279

REVISION LOG

CODE	DATE	SHEET	DESCRIPTION	BY
1	2/4/08	1-9	ADDED SITE NAMES	TLH
2	2/5/08	3	ADDED CEILING SUPPORT POST	DRL
3	2/11/2008	7 & 9	WALLS CHANGED FROM 16' OC TO 12' OC	BR

BUILDINGS, INC. <b>THERMO BOND</b> P.O. Box 445 Elk Point, SD			
Scale: 1/4" = 1'	Title: REVISION LOG GENERAL NOTES		
Date: 1/31/08	Revised: 2/4/08 2/11/08		Drawing Number: AGB8015
Drawn By: TLH	Approved By:		PAGE 2 OF 9
<small>COMPUTER AIDED DRAWING AGB8015G</small>			