

BUILDING EXTERIOR	
<input checked="" type="checkbox"/>	BUFF
<input type="checkbox"/>	OZARK
<input type="checkbox"/>	GREY
<input type="checkbox"/>	OTHER _____

PROJECT
ARIZONA DEPT. PUBLIC SAFETY

JOB NO.

0712-01

SITE NAME

KEYSTONE PEAK &
CASA GRANDE MOUNTAIN, AZ

SIZE

(2) 20' W O.D. X 24' L O.D. X 10' H I.D.

DOUBLE WIDE

<u>DRAWING TITLE</u>	<u>DRAWING NUMBER</u>
DRAWING INDEX_____	AGB8015 PAGE 1 OF 9
REVISION LOG_____	AGB8015 PAGE 2 OF 9
INTERIOR LAYOUTS_____	AGB8015 PAGE 3 OF 9
ELEVATION VIEWS_____	AGB8015 PAGE 4 OF 9
ELEVATION VIEWS_____	AGB8015 PAGE 5 OF 9
BUILDING CONSTRUCTION DETAILS_____	AGB8015 PAGE 6 OF 9
BUILDING CONSTRUCTION DETAILS_____	AGB8015 PAGE 7 OF 9
BUILDING CONSTRUCTION DETAILS_____	AGB8015 PAGE 8 OF 9
BUILDING CONSTRUCTION DETAILS_____	AGB8015 PAGE 9 OF 9
BUILDING SKID ASSEMBLY_____	15B1024 PAGE 1 OF 1
BUILDING FOUNDATION ASSEMBLY_____	S15B1024 PAGE 1 OF 1

23 OF 33

A-139278

USAGE	UNMANNED TELECOMMUNICATION SHELTER
CONSTRUCTION TYPE	<u>VB</u>
OCCUPANCY GROUP	<u>S-2</u>
STORIES	<u>1</u>
BASIC WIND SPEED	____ MPH
FLOOR LOAD	____ PSF
SNOW LOAD	____ PSF
FLOOR AREA	<u>480 SQ.FT.</u>
BUILDING HGT.	<u>11'-10"</u>
WIND EXPOSURE CATEGORY	<u>C</u>
SEISMIC DESIGN CATEGORY	<u>D</u>

CODES:
2003 INTERNATIONAL BUILDING CODE (IBC)
2003 INTERNATIONAL MECHANICAL CODE (IMC)
2002 NATIONAL ELECTRICAL CODE (NEC)
1994 UPC

BUILDINGS, INC.		
THERMO BOND		
P.O. Box 445 Elk Point, SD		
Scale:	NONE	Title:
Date:	1/30/08	DRAWING INDEX
Drawn By:	TLH	Revised:
Approved By:		2/4/08
		Drawing Number:
		AGB8015
		PAGE 1 OF 9
COMPUTER AIDED DRAWING AGB015F		